

GOVERNMENT OF TAMILNADU

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SANITARY CERTIFICATE

YEAR 2020-2021

APPEDIX - 3

(Chapter III Rule : 24)

TamilNadu Educational Rules

I hereby declare that I have inspected the School PON VIDYA MANDIR SENIOR SECONDARY SCHOOL, MANMANGALAM, KARUR- 639 006 . Building and premises on the day of 08.10.2020 and certify .

- : That the accommodation provided for each the rooms are sufficient for the maximum number of pupil taught there in.
- : That is properly ventilated and lighted.
- : That the building is maintained in substantial repairs.
- : That it is neat and clean.
- : That the Latrine arrangements are adequate and satisfactory.
- : That the supply of drinking water is wholesome.
- : That what in all necessary aspects and the sanitation is GOOD.

This Certificate is Valid upto academic year 2020-2021 only.

15/10/2020  
8/10/2020

K.Dis.No: 5908 / E4 /2020 Date : 08/10/2020

Office of the Deputy Director of Health Services, Karur.



/Counter signed/

*P. S. Jeyaraj*

**CHAIRMAN  
PON VIDYA MANDIR  
SF No: 175, NH-7,  
MANMANGALAM, KARUR - 639 006.**

Deputy Director of Health Services,  
C Health Services, KARUR.  
Karur.

*P. S. Jeyaraj*  
8/10/2020

This Certificate is issued subject to the following condition:

- 1) The Garbage generated within the School premises should be collected and disposed of properly by appointing require sanitary staff.
- 2) On any account the Garbage should not be burnt.
- 3) The Workmen should be educated to prevent the usage of plastics in the School premises and no one should bring plastic carry bags use and throw Tumblers to the premises.
- 4) N.O.C (or) License under PFA Act, 1954,
- 5) As per TNPH Act, 1939 NOC Occupation Certificate should be obtained from the Deputy Director of Health Services, to run a school /college /institute within the premises.
- 6) Fire precautional measures, and First Aid box, should be provided in the campus.
- 7) This Certificate issued is liable to be cancelled at time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper of the building as well as toilets in the school/college/institute.
- 8) Child Labour should not be engaged on any account.
- 9) Sign Board regarding No Smoking Zone. Here Smoking and Spiting is an offence should be exhibited.
- 10) About Dengu and Covid 19 awareness should be given to all.

150. *[Signature]*  
8.10.2017

MANANGALAM, KARUR - 630 004  
SF No: 125, NN-7  
POM VIDYA MANDIR  
CHAIRMAN

-: TEST WATER BEFORE TASTE :-



**TAMIL NADU WATER SUPPLY & DRAINAGE BOARD**  
**DISTRICT LEVEL WATER TESTING LABORATORY**

TWAD Board, No 46 Pugalur Road Karur 639002

**TEST REPORT**

Ph:04324-221455

From Er. S.Yogaraj ME Assistant Engineer TWAD Board, DWT Lab I/c, Karur	To The Principal Pon Vidya Mandir SF No,175,NH-7, Manmangalam ,Karur-639006.
---	--

Lr.No: 33639-33640 /JWA/TWAD Lab/KRR/2019/Dated: 31.01.2020

Sir,

Sub: Examination of water sample - Report furnished - Reg.

1) T.O Invoice No. 4608 /dt 30.01.2020 for Rs 1652/-

The results of analysis for the water sample sent under reference is furnished below.

Sample No	33639-33640		
Date of Collection	31.01.2020		
Date of Receipt	31.01.2020		
Scheme	PVT		
Source	RO		
Location of Sampling	Inside the Campus		
Habitation	Manmangalam		
Panchayat	Manmangalam		
Union	Karur		
Collected By	R Sathya Devan		
<b>BIS 10500 : 2012</b>	<b>Acceptable limit</b>	<b>Permissible limit in the absence of alternate source</b>	<b>Result for Water sample No:</b>
<b>I PHYSICAL EXAMINATION</b>			<b>33639</b>
1 Appearance	--	--	Clear
2 Colour (Pt.Co - scale)	5	15	Colourless
3 Odour	Agreeable	0	None
4 Turbidity NT units	1	5	0
5 Total dissolved solids, mg/L	500	2000	149
6 Electrical conductivity micro mho/cm	--	--	213
<b>II CHEMICAL EXAMINATION</b>			
7 pH	6.5 to 8.5	6.5 to 8.5	7.32
8 Ph-Alkalinity as CaCO <sub>3</sub> mg/L			0
9 Total Alkalinity CaCO <sub>3</sub> mg/L	200	600	40
10 Total Hardness as CaCO <sub>3</sub> mg/L	200	600	78
11 Calcium as Ca mg/L	75	200	15
12 Magnesium as Mg mg/L	30	100	10
13 Sodium as Na mg/L	--	--	10
14 Potassium as K mg/L	--	--	2
15 Iron as Fe mg/L	0.3	0.3	0.00
16 Manganese as Mn mg/L	0.1	0.3	0.00
17 Free Ammonia as NH <sub>3</sub> mg/L	0.5	0.5	0.00
18 Nitrite as NO <sub>2</sub> mg/L	--	--	0.00
19 Nitrate as NO <sub>3</sub> mg/L	45	45	1
20 Chloride as Cl mg/L	250	1000	36
21 Fluoride as F mg/L	1	1.5	0.2
22 Sulphate as SO <sub>4</sub> mg/L	200	400	9
23 Phosphate as PO <sub>4</sub> mg/L	--	--	0.00
24 Tidy's Test 4hrs as O <sub>2</sub> mg/L	--	--	0.08
25 Free residual chlorine mg/L	0.2	1.0	0.0
<b>III BACTERIOLOGICAL EXAMINATION</b>			
1 Fecal coliform (colonies per 100 ml)	0	0	0

**CHAIRMAN**  
**PON VIDYA MANDIR**

SF No: 175, NH-7,  
**MANMANGALAM, KARUR - 639 006.**

REPORT: 33639-33640 : The water is Physically ,chemically Potable and Bacteriologically not Contaminated

31/1/20  
 Assistant Engineer  
 TWAD Board, DWT Lab I/c,  
 Karur